



## Gas Oil

Row	Properties	Unit	Limit	Test Method
1	Density @ 15 °C	Kg/m <sup>3</sup>	810-850	ASTM D 1298
2	Distillation:			ASTM D 86
3	Recovered @ 150 °C	Vol%	report	ASTM D 86
4	Recovered @ 300 °C	Vol%	report	ASTM D 86
5	Recovered @ 357 °C	Vol%	90 min	ASTM D 86
6	F.B.P	°C	358 max	ASTM D 86
7	Colour	-	3 max	ASTM D 1500
8	Flash Point	°C	54 min	ASTM D 93
9	Sulphur Total	Wt%	1 max	ASTM D 1552
10	Corrosion-3hrs @ 100°C	-	1a	ASTM D 130
11	Viscosity Kinematic @37.8 °C	c.St	2.5-5.5	ASTM D 445
12	Cloud Point	°C	2.0 max	ASTM D 2500
13	Pour Point	°C	-3.0 max	ASTM D 97
14	Carbon Residue (on 10% Bottoms)	Wt%	0.1max	ASTM D 189
15	Ash	Wt%	0.01 max	ASTM D 482
16	Water & Sediment	Vol%	0.05 max	ASTM D 2709
17	Cetane Index	-	50 min	ASTM D 976